


## Magnetic Lock Power Supplies / Charger

---

These power supplies provide backup DC power for magnetic locks when primary (AC) power is interrupted. Each of these power supplies features filtered and electronically regulated outputs, short circuit and thermal overload protection and each has a built-in battery charger for sealed lead acid or gel type batteries. The enclosure will accommodate up to two (2) 12 VDC / 7AH batteries. **Batteries are not included with these systems.**



### 1215-130

- 115 VAC, .6 amp input
- 12 or 24 VDC, selectable output
- 1 amp total supply current
- Maximum charge current .4 amp

### 1215-131

- 115 VAC, 1.45 amp input
- 12 or 24 VDC, selectable
- 2.5 amp total supply current
- Maximum charge current .7 amp
- Zero voltage drop upon transfer to battery power
- AC Fail supervision (form C contact)
- Low battery & battery presence supervision

### 1215-132

- 115 VAC, 1.45 amp input
- 12 or 24 VDC, selectable output
- 4 amp total supply current @ 12 VDC
- 3 amp total supply current @ 24 VDC
- Maximum charge current .7 amp
- Zero voltage drop upon transfer to battery power
- AC Fail supervision (form C contact)
- Low battery & battery presence supervision

### 1215-133

- 115 VAC, 1.9 amp input
- 12 or 24 VDC, selectable
- 6 amp total supply current
- Maximum charge current .7 amp
- Zero voltage drop upon transfer to battery power
- AC Fail supervision (form C contact)
- Low battery & battery presence supervision

<b>Magnetic Lock Power Supplies</b>		
<b>P/N</b>	<b>Description</b>	
1215-130	Altronix AL125ULX 12 / 24 VDC @ 1 amp	
1215-131	Altronix AL300ULX 12 / 24 VDC @ 2.5 amp	
1215-132	Altronix AL400ULX 12 VDC @ 4 amp; 24 VDC @ 3 amp	
1215-133	Altronix AL600ULX 12 / 24 VDC @ 6 amp	

<b>Agency Listings</b>				
<b>Agency</b>	<b>1215-130</b>	<b>1215-131</b>	<b>1215-132</b>	<b>1215-133</b>
UL Listed: Access Control Systems (UL 294)	X	X	X	X
CUL Listed: CSA Standard C22.2 No.205-M1983	X	X	X	X
MEA: NYC Department of Building Safety Approved	X	X	X	X
NFPA 101 (Life Safety)	X			
UL Listed: Burglar Alarms Systems (UL 603)		X	X	
UL Listed: Hospital Signaling / Nurse Call Equipment (UL 1069)		X	X	
UL Listed: Power Supply for Fire Signaling Systems (UL 1481)		X	X	X
CSFM: California State Fire Marshall Approved		X	X	X
NFPA 72: Compliant		X	X	X
FM Approved			X	X