

## ANNUNCIATOR CONTROL UNIT

### **APPLICATION**

The TekTone® PK-2019 (PK2019) Annunciator Control Unit is a general purpose annunciator control unit that is used with the CM-800 Emergency Call System and the DS-100 Door Sentry System.

The PK-2019 provides tone signal, tone silencing, tone-silenced indication, auxiliary signal relay, and 24 VDC for accessory device operation.

#### **FEATURES**

- Low-voltage operation
- Rugged extruded aluminum case.
- Positive screw terminals

#### **SPECIFICATIONS**

Dimensions: 5.0"High (127 mm)

Width: 2.375" (61 mm) Depth: 2.25" (58 mm)

Construction: Quality electronic components mounted on a PC

board encased in a rugged extruded aluminum

housing.

Connections: Screw terminals

Power Required: 16 VAC 30 VA max.

Output Current: 1 Amp. maximum

Tone Speaker: 45 ohms (up to 3 in parallel)
Tone-Off Lamp: .04 Amp. (up to 3 in parallel)

#### REOUIRED COMPONENTS

PS-30A UL Transformer, 16VAC, 30VA

CM-800 Series Annunciator Panel

-or-

DS-100 Series Speaker Panel



PK-2019

# ARCHITECTS' AND ENGINEERS' SPECIFICATIONS

The annunciator control unit shall be TekTone® PK-2019 or approved equivalent as supplied by *LEE DAN®*. It shall be used with the CM-800 Emergency Call System and/or the DS-100 Door Sentry System.

The PK-2019 shall be capable of generating either a steady or intermittent alarm tone.

Screw terminals shall be provided for connections. The control unit shall be of rugged construction and modular integrated circuit design.

800-231-1414 • 631-231-1414 155 Adams Avenue • Hauppauge, NY 11788-3699 Fax 631-231-1498 • www.*LEEDAN*.com ANNUNCIATORS • WIRE & CABLE • NURSE-CALL INTERCOMS • MAILBOXES • DIRECTORIES • SIGNS