

UL EMERGENCY SHOWER SWITCH

APPLICATION

The SF-337C Emergency Shower Switch is for any location where activation of an emergency signal is required. The design is such that it may be located anywhere in a shower, bath or tub room, regardless of environmental conditions.

The combination of rubber-grommetted mounting screws, rubber mounting gasket, and completely sealed front faceplate make it waterproof (if properly installed). Electronic components are mounted on a circuit board, including an industry-proven reliable reed switch for circuit initiation. The activating magnet is mounted on the large pull-down lever, which is completely sealed in plastic. The indicator LED is also completely sealed.

Due to the flexibility of its design, the SF-337C may be used as a pull cord or as a pull down activated emergency switch. The pull cord supplied may be used for emergency call activation, or if desired, the large 1.1" (28 mm) red pulldown lever may be used. Dome light and system annunciation vary according to the manner in which the SF-337C is connected.

FEATURES

- UL® 1069 Listed
- Waterproof—if installed according to manufacturer's instructions
- Call-placed indicator • Call cancel at point of origin
- Attractive, flame-retardant (UL® 94V-0) plastic faceplate
- 1.1" (28 mm) wide pull-down lever

SPECIFICATIONS

Dimensions: Height: 4.5" (114 mm)
Width: 2.8125" (72 mm)
Depth: 1.625" (41 mm)
Projects: 0.6875" (17 mm)
(including pull down lever)

Construction: Flame-retardant (UL® 94V-0) plastic

Connections: Plug-in type.

Housing: Single gang ring with square box.

REQUIRED COMPONENTS

Tek-CARE® NC300II,

or

NC200, NC150, NC110 Nurse Call Systems

or

Tek-CARE®500 Wireless Emergency Call System



SF-337C
Emergency Shower Switch
(Cord Not Shown)

ARCHITECTS' AND ENGINEERS' SPECIFICATIONS

The emergency shower switch shall be TekTone® SF-337C or approved equal as supplied by LEE DAN®. Operation of emergency signals shall be accomplished by a short pull on the nylon cord or by pulling down on the RED lever marked **EMERGENCY**. The red **CALL-PLACED** indicator shall flash to assure the patient that the call has been placed. The emergency shower switch shall be waterproof if mounted according to manufacturer's instructions. If mounted correctly, the faceplate shall be sealed from the electronic components. The switching mechanism shall consist of a reliable reed switch with a sealed magnet actuator.

The SF-337C shall be UL® 1069 Listed.